CR120

Optimized circular fire damper up to 120'
















Table of content

Table of content

| Declaration of performance | 3 |
|---|----|
| Product presentation CR120 | 4 |
| Range and dimensions CR120 | 4 |
| Evolution - kits | 5 |
| Options - at the time of order | 7 |
| Storage and handling | 8 |
| Installation | 8 |
| Operation and mechanisms | 19 |
| Electrical connection | 22 |
| Weights | 24 |
| Selection graphs | 24 |
| Example | 25 |
| Selection data | 25 |
| Correction factor ΔL | 26 |
| Sample order | 26 |
| Approvals and certificates | 26 |
| Explanation of the abbreviations and pictograms | |

| pivtogrania |
|--|
| V DC = Volt direct current |
| E.ALIM = power supply magnet |
| E.TELE = power supply motor |
| V = volt |
| W = watt |
| Auto = automatic |
| Tele = remote controlled |
| Pnom = nominal capacity |
| Pmax = maximum capacity |
| GKB (type A) / GKF (type F): "GKB" stands |
| for standard plasterboards (type A accor- |
| ding to EN 520) while "GKF" plasterboard |
| offer a higher fire resistance for a similar |
| plate thickness (type F according to EN |
| |

520)

Cal-Sil = calcium silicate

KIT = kit (delivered separately for repair or upgrade) PG = connection flange to the duct Sn = free air passage

 ζ [-] = pressure loss coefficient

Q = air flow

 ΔP = static pressure drop v = air speed in the duct

Lwa = A-weighted sound power level Lw oct = sound power level per octave

midband

dB(A)a = A-weighted decibel value

 $\Delta L = correction factor$

| | higher net building volume | × | optimal acoustic performance |
|----------|--|--------------|--|
| Sn D | optimal free air passage and minimal pressure loss | EN 1751 C | air-tightness class C according to EN1751 |
| | suitable for built-in installation | | suitable for installation remote from the wall |
| BASTA OK | sealing with fire resistant stone wool boards allowed, also for asymmetric opening | | |

OP = option (delivered with the product)

DECLARATION OF PERFORMANCE

GE_DOP_Rf-t_C11_EN = D-02/2015

| | יי פיוול מבין מבוונון במנים וו במבים מיוב ליו מול מליבי | | Circular fire damper | | | | | | |
|--|---|--|--|--|--|---|--|--|--|
| 2. Identification of the construction product: | ruction product: | | CR120 | | | | | | |
| 3. Intended use(s) of the construction product: | struction product: | | fire | in conjunction with | partitions to maintain | damper to be used in conjunction with partitions to maintain fire compartments in heating. Ventilating and air conditioning installations. | nd air conditioning ins | itallations | |
| 4. Name and contact address of the manufacturer: | of the manufacture | | Rf-Technologies NV, Lange Ambachtstraat 40, B-9860 Oosterzele | vachtstraat 40, B-986 | 30 Oosterzele | n n | n | | |
| System of assessment and tion product: | verification of cons | System of assessment and verification of constancy of performance of the construc- tion product: | System 1 | | | | | | |
| 6. In case of the declaration oby a harmonised standard: | of performance con: | 6. In case of the declaration of performance concerning a construction product covered by a harmonised standard: | Notified factory production control certification body BCC inspection of the manufacturing plant and of factory proc constancy of performance BC1-606-0464-15650.02-2517 | ntrol certification boing plant and of factor 606-0464-15650.02- | dy BCCA with identific ry production control :2517 | Notified factory production control certification body BCCA with identification number 0749 performed the determination of the product type on the basis of type testing (including sampling), the initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control under system 1 and issued the certificate of constancy of performance BC1-606-0464-1565002-2517 | nation of the product t d evaluation of factory | ype on the basis of type testing (includ r production control under system 1 an | ing sampling), the d issued the certifi |
| 7. Declared performance according to EN 15650:2010 | ording to EN 15650 | | (Fire resistance according to EN 1366-2 and classifications according to EN 13501-3) | 1366-2 and classific | ations according to El | N 13501-3) | | | |
| Essential characteristics | | | | | | | | Performance | |
| Range | Wall type | Wall | | Sealing | | | Instal | Installation Classification | |
| Ø 100-315 mm | Rigid wall | Reinforced concrete ≥ 110mm | | Mortar | | | - | El 120 (vei ↔ o) S - (500 Pa) | |
| | | Aerated concrete ≥ 100mm | | Mortar | | | - | El 90 (v _e i ↔ o) S - (500 Pa) | |
| | | | | Mineral wool + co | ating $\geq 150 \text{ kg/m}^3 + \epsilon$ | Mineral wool + coating \geq 150 kg/m ³ + endothermic coated casing | 1 | El 120 (v _e i ↔ o) S - (300 Pa) | |
| | | | | Galvanised duct + | Galvanised duct + PROMASTOP®-CB 2x50mm | 30mm | 2 | El 90 (v _e i ↔ o) S - (300 Pa) | |
| | | | | Galvanised duct + | Galvanised duct + GEOFLAM® F 45mm + mortar | + mortar | 2 | El 120 (v _e i ↔ o) S - (500 Pa) | |
| | Rigid floor | Reinforced concrete ≥ 150mm | | Mortar | | | - | El 120 (h _o i ↔ o) S - (500 Pa) | |
| | | Aerated concrete ≥ 100mm | | Mortar | | | - | El 90 (h _o i ↔ o) S - (500 Pa) | |
| | | Aerated concrete ≥ 150mm | | Mineral wool + co | ating $\geq 150 \text{ kg/m}^3 + \epsilon$ | Mineral wool + coating ≥ 150 kg/m³ + endothermic coated casing | - | El 120 (h₀ i ↔ o) S - (300 Pa) | |
| | Flexible wall | Metal studs gypsum plasterboard Type A (EN 520) ≥ 100mm | 4 (EN 520) ≥ 100mm | Mineral wool + co | ating $\geq 150 \text{ kg/m}^3 + \epsilon$ | Mineral wool + coating $\geq 150 \text{ kg/m}^3$ + endothermic coated casing | 1 | El 60 (v _e i ↔ o) S - (300 Pa) | |
| | | Metal studs gypsum plasterboard Type F (EN 520) ≥ | F (EN 520) ≥ 100mm | Mineral wool + co | ating $\geq 150 \text{ kg/m}^3 + \epsilon$ | Mineral wool + coating $\geq 150 \text{ kg/m}^3$ + endothermic coated casing | 1 | El 120 (v _e i ↔ o) S - (300 Pa) | |
| | | | | Galvanised duct + | Galvanised duct + PROMASTOP®-CB 2x50mm | 50mm | 2 | El 90 (v _e i ↔ o) S - (300 Pa) | |
| Ø 100-250 mm | Rigid wall | Aerated concrete ≥ 100mm | | Mortar | | | - | El 120 (v _e i ↔ o) S - (500 Pa) | |
| | Flexible wall | Metal studs gypsum plasterboard Type A (EN 520) ≥ 100mm | 4 (EN 520) ≥ 100mm | Mineral wool ≥ 40 | Mineral wool ≥ 40 kg/m³ + cover plates | | 1 | El 60 (v _e i ↔ o) S - (500 Pa) | |
| I Type of installatic | lype of installation: built-in, 0-360° | | | | 2 Type of in | Type of installation: remote from the wall, 0/180° | | \bigoplus_{\bullet} | |
| Nominal activation conditions/sensitivity: | s/sensitivity: | | | | | | | Pass | |
| Response delay (response time): closure time | ne): closure time | | | | | | | Pass | |
| Operational reliability: cycling | 6 | | | | | | | MFUS - 50 cycles; MMAG - 300 cycles; B(L)F(T) - 10000 cycles; BFL(T) - 10000 cycles | cycles; B(L)F(T) :ycles |
| Durability of response delay: | | | | | | | | Pass | |
| Durability or operational reliability: Protection against corrosion according to EN 60068-2-52: | ability: according to EN 600 | 68-2-52: | | | | | | Pass | |
| Damper casing leakage according to EN 1751: | ding to EN 1751: | | | | | | | ≥ class C | |
| The performance of the pro declaration of performance is | duct identified in poissued under the so. | 8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. | ared performance in point 7. Thi fied in point 4. | S | | | Signed for al | Signed for and on behalf of the manufacturer by: Barbara Willems, Technical Manager | Pf-+ |
| | | | | | | | | will even | |
| | | | | | | | | | |

Product presentation CR120

Product presentation CR120


Optimized circular fire damper with a fire resistance up to 120 minutes. A minimal pressure loss is guaranteed thanks to the thin blade, the fusible link aligned with the blade, and the transmission located outside the tunnel. The damper is available in small diameters (starting from 100 mm). Its galvanized steel tunnel contributes to the light weight of the damper.

Fire dampers are installed where air ducts penetrate fire-resistant compartment walls. Their role is to restore the fire resistance grade of the penetrated wall and to prevent smoke propagation. Fire dampers are distinguished by their degree of fire resistance, by their aeraulic properties as well as by their installation ease. Rf-Technologies' fire dampers are all CE marked. They can be equipped with various types of mechanisms depending on the specific needs linked to the project or to the local regulations.

- easy to install
- ☑ optimal free air passage and minimal pressure loss
- ☑ optimal acoustic performance
- ✓ air-tightness class C according to EN1751
- suitable for built-in installation
- suitable for installation remote from the wall
- suitable for rigid wall, rigid floor and light wall (metal stud gypsum plasterboard wall)
- sealing with fire resistant stone wool boards allowed, also for asymmetric opening
- tested according to EN 1366-2 up to 500 Pa
- operating mechanism outside the wall
- maintenance-free
- for indoor use
- operating temperature: max. 50°C
- 1. casing in galvanised steel
- 2. damper blade
- 3. operating mechanism
- 4. rubber sealing ring
- 5. intumescent strip
- 6. base plate for thermo-electrical fuse
- 7. positioning plate
- 8. sealing ring for damper blade
- 9. fusible link
- 10.product identification

Range and dimensions CR120

Exceeding damper blade: 20 mm for Ø 315 mm




















| | MFUS | MMAG | BFL(T) |
|---|------|------|--------|
| P | 70 | 109 | 60 |
| Q | 123 | 173 | 80 |
| Z | 62 | 112 | 40 |

Evolution - kits

| FAGIRGIOII - WITS | | |
|-------------------|----------------|--|
| J.D. | KITS MFUS | Automatic unlocking mechanism with fusible link |
| | KITS MMAG | Upgradeable automatically unlocking mechanism |
| Mo: | KITS BFL24 | Spring return actuator BFL 24V |
| M°2. | KITS BFL24-ST | Spring return actuator BFL 24V with plug (ST) |
| M°2. | KITS BFLT24 | Spring return actuator BFL 24V with thermo-electric fuse (T) |
| H 2. | KITS BFLT24-ST | Spring return actuator BFL 24V with thermo-electric fuse (T) and plug (ST) |

| M°2. | KITS BFL230 | Spring return actuator BFL 230V |
|--|-------------------|--|
| M°Z. | KITS BFLT230 | Spring return actuator BFL 230V with thermo-electric fuse (T) |
| 11 0 L. | KITS BFN24 | Spring return actuator BFN 24V (BFN kits must be used instead of BFL kits for fire dampers produced before 1/7/2015) |
| E Comment | KITS VD MMAG FDCU | Natural magnet 24/48 V DC + FDCU |
| E CONTRACTOR OF THE PARTY OF TH | KITS VM MMAG FDCU | Electromagnet 24/48 V DC + FDCU |
| | KITS FDGU MFUS(P) | Unipolar beginning and end of range switch |
| | KITS FDCU MMAG | Unipolar beginning and end of range switch |
| | KITS FDCB MMAG | Bipolar beginning and end of range switch |
| E C | KITS SN2 BFL/BFN | Bipolar beginning and end of range switch |
| " | KITS ME MMAG | Resetting motor ME 24V/48V (DC) |



Options - at the time of order



ш

Inspection opening to visually determine the state and the position of the damper, by using an endoscope.

Storage and handling

Storage and handling

As this product is a safety element, it should be stored and handled with care.

Avoid:

- any kind of impact or damage
- contact with water
- deformation of the casing

It is recommended:


- to unload in a dry area
- not to flip or roll the product to move it
- not to use the damper as a scaffold, working table, etc.
- not to store smaller dampers inside larger ones


Installation

General points

- The installation must comply with the classification report and the installation manual delivered with the product.
- Axis orientation: see the declaration of performance.
- Avoid obstruction of adjoining ducts.
- Product installation: always with closed damper blade.
- Verify if the blade can move freely.
- Please observe safety distances with respect to other construction elements.
- The air tightness class will be maintained if the damper is installed according to the installation manual.
- Rf-t fire dampers are always tested in standardized constructions according to EN 1366-2. The achieved results are valid for similar supporting constructions with a fire resistance, thickness and density equal or superior to the supporting construction used during the test.
- The damper must remain accessible for inspection and maintenance.
- Schedule at least two running checks each year.









Installation in rigid wall and floor

The product was tested and approved in:

| Range | Wall type | | Sealing | Classification |
|--------------|-------------|-----------------------------|---------|---|
| Ø 100-315 mm | Rigid wall | Reinforced concrete ≥ 110mm | Mortar | EI 120 ($v_e i \leftrightarrow o$) S - (500 Pa) |
| Ø 100-315 mm | Rigid wall | Aerated concrete ≥ 100mm | Mortar | El 90 (v _e i ↔ o) S - (500 Pa) |
| Ø 100-315 mm | Rigid floor | Reinforced concrete ≥ 150mm | Mortar | EI 120 (h₀ i ↔ o) S - (500 Pa) |
| Ø 100-315 mm | Rigid floor | Aerated concrete ≥ 100mm | Mortar | El 90 (h _o i ↔ o) S - (500 Pa) |
| Ø 100-250 mm | Rigid wall | Aerated concrete ≥ 100mm | Mortar | El 120 (v _e i ↔ o) S - (500 Pa) |








Installation in flexible wall - metal stud gypsum plasterboard wall


The product was tested and approved in:

| Range | Wall type | | Sealing | Classification |
|--------------|---------------|---|--------------------------------------|---|
| Ø 100-250 mm | Flexible wall | Metal studs gypsum plasterboard Type A (EN 520) ≥ 100mm | Stone wool ≥ 40 kg/m³ + cover plates | El 60 (v _e i ↔ o) S - (500 Pa) |











Installation in flexible and rigid wall, sealing with rigid rock wool boards with coating


The product was tested and approved in:

| Range | Wall type | | Sealing | Classification |
|--------------|---------------|---|--|---|
| Ø 100-315 mm | Rigid wall | Aerated concrete ≥ 100mm | Stone wool + coating ≥ 150 kg/m³ + endothermic coated casing | EI 120 ($v_e i \leftrightarrow o$) S - (300 Pa) |
| Ø 100-315 mm | Flexible wall | Metal studs gypsum plasterboard Type A (EN 520) ≥ 100mm | Stone wool + coating ≥ 150 kg/m³ + endothermic coated casing | El 60 (v _e i ↔ o) S - (300 Pa) |
| Ø 100-315 mm | Flexible wall | Metal studs gypsum plasterboard Type F (EN 520) ≥ 100mm | Stone wool + coating ≥ 150 kg/m³ + endothermic coated casing | EI 120 (v _e i ↔ o) S - (300 Pa) |







The opening around the damper is sealed with 2 layers of 50 mm-thick mineral wool panels with fire resistant coating on one side (type PROMASTOP-CB 50 or HILTI CFS-CT B).




The joints on these 2 layers must be installed staggered and covered all around the edge with endothermic coating (type PROMASTOP-E or HILTI CFS-S-ACR).




The casing of the fire damper is coated with a layer (>1 mm) of endothermic coating (type PROMASTOP-E or HILTI CFS-CT).



The damper does not need to be centered in the opening (with max dimensions fire damper + 600 mm). The maximal distance between the damper and the edge of the opening is 400 mm.







Installation in rigid floor, sealing with rigid rock wool boards with coating


The product was tested and approved in:


| Range | Wall type | | Sealing | Classification |
|--------------|-------------|--------------------------|--|-----------------------------------|
| Ø 100-315 mm | Rigid floor | Aerated concrete ≥ 150mm | Stone wool + coating ≥ 150 kg/m ³ + endothermic coated casing | El 120 (h₀ i ↔ o) S - (300 Pa) |







The opening around the damper is sealed with 2 layers of 50 mm-thick mineral wool panels with fire resistant coating on one side (type PROMASTOP-CB 50 or HILTI CFS-CT B).











The casing of the fire damper is coated with a layer (>1 mm) of endothermic coating (type PROMASTOP-E or HILTI CFS-CT).




The damper does not need to be centered in the opening (with max dimensions fire damper + 600 mm). The maximal distance between the damper and the edge of the opening is 400 mm.




Installation remote from the wall, sealing and insulation with rigid rock wool boards with coating


The product was tested and approved in:

| Range | Wall type | | Sealing | Classification |
|--------------|---------------|---|--|---|
| Ø 100-315 mm | Rigid wall | Aerated concrete ≥ 100mm | Galvanised duct + PROMASTOP®-CB 2x50mm | El 90 (v _e i ↔ o) S - (300 Pa) |
| Ø 100-315 mm | Flexible wall | Metal studs gypsum plasterboard Type F (EN 520) ≥ 100mm | Galvanised duct + PROMASTOP®-CB 2x50mm | El 90 (v _e i ↔ o) S - (300 Pa) |







1.




2.



- 1. An opening with maximal dimensions "A" is made in the wall. For a light partition wall, follow the wall assembly under "Installation in flexible or rigid wall Sealing with fire resistant rigid panels of stone wool".
- 2. The fire damper is mounted remote from the wall at the end of a metal duct. The fire damper is supported by a clamping ring of the same diameter as the damper, held in place by threaded rods "C". The duct is supported every 1500 mm. The suspensions consist of threaded rods "C" and U-shaped steel profiles "D". A free space of maximum 25 mm is left between the threaded rods and the vertical walls of the stone wool casing "B".




3. The opening around the duct is sealed with stone wool plates type Promastop CB ("G"). The edges are sealed and maintained in place with PROMASTOP E coating.




4. The duct is covered over its entire length with stone wool plates "G". To adhere to the duct, the plates are completely coated on one side with PROMASTOP E and affixed to the duct with steel screws and washers "E".

The damper casing is covered with stone wool plates "G" for 171 mm. A free space should be left around the mechanism to guarantee access.

The joints between the plates, between the wall and the plates as well as the screws and washers are filled with coating PRO-MASTOP E.



5. An additional stone wool panel type "G", coated with PRO-MASTOP E, is applied in the opening between the tunnel of the damper blade and the stone wool panels.





6.


Installation remote from the wall + GEOFLAM

The product was tested and approved in:


| Range | Wall type | | Sealing | Classification |
|-----------------|-------------|--------------------|-------------------------------------|--|
| Ø 100 215 ····· | Distiducall | Aerated concrete ≥ | Galvanised duct + GEOFLAM® F 45mm + | El 120 (v _e i ↔ o) S - (500 |
| Ø 100-315 mm | Rigid wall | 100mm | mortar | Pa) |








1.










- 1. An opening with maximal dimensions "A" is made in the wall.
- 2. The fire damper is mounted remote from the wall at the end of a metal duct. The duct is supported every 1000 mm.

 The suspensions consist of threaded rods "C" and U-shaped steel profiles "D". A free space of maximum 25 mm is left between the threaded rods and the vertical walls of the casing "B".









4. The GEOFLAM F plates stop at a distance of 20 mm from the wall. The free space is filled with fibrous plaster.


The same filling is applied to seal off the connection between the GEOFLAM F plates and the damper casing.




5. The threaded rods are covered with U-shaped plates of GE-OFLAM (Ø 90 mm) and affixed with glue and fibrous plaster. The profiles are covered with U-shaped shells GEOFLAM 100 x 60 mm, which are affixed to the underside of the shaft with GEOCOL (GEOSTAFF) cement plaster.




Inspection of the damper



Remove the air-tight plug from the damper.



Insert the camera of the endoscope (for example Inspecam Rf-t) through the opening and inspect the inside of the damper.



After inspection, replace the air-tight plug thoroughly on the damper opening. The position is crucial in order to maintain the air-tightness of the fire damper.

Maintenance

- No specific maintenance required.
- Schedule at least two running checks each year.
- Remove dust and all other particles before start-up.
- Follow the local maintenance regulations (i.e. BS9999 Annex V; NF S 61-933) and EN13306.

Operation and mechanisms



MFUS(P) Automatic unlocking mechanism

The operating mechanism MFUS(P) automatically unlocks the blade when the temperature in the duct exceeds 72°C. The damper can also be unlocked and reset manually.

- 1. unlocking button
- 2. resetting handle
- 3. cable entrance



Options - at the time of order

FDCU

Unipolar beginning and end of range switch

Unlocking

- **manual unlocking**: press the unlocking button (1).
- **automatic unlocking**: the fusible link melts when the temperature reaches 72°C in the duct.
- remote unlocking: n/a

Resetting

- manual resetting: turn the resetting handle (2) 90° clockwise (or use a 10 mm hex key).
- motorised resetting: n/a

Caution:



▲ The mechanism may never be tested on its own, without being attached to the damper. Such a test might damage the mechanism or the operator might be injured.

Operation and mechanisms



MMAG Upgradeable automatically unlocking mechanism

The fusible link of the upgradeable unlocking mechanism MMAG automatically unlatches the damper blade when the temperature in the duct rises above 72°C. The damper must be reset manually. The automatic MMAG mechanism is easy to upgrade to a: - Remote controlled mechanism (remote electrical unlocking). - Motorised mechanism (remote resetting).

- 1. unlocking button
- 2. resetting handle
- 3. cable entrance



Options - at the time of order

| VD | Natural magnet 24/48 V DC (order with FDCU) |
|------|--|
| VM | Electromagnet 24/48 V DC (order with FDCU) |
| FDCU | Unipolar beginning and end of range switch |
| FDCB | Bipolar beginning and end of range switch (incl. FDCU) |
| ME | Resetting motor ME 24V/48V (DC) |

Unlocking

- **manual unlocking**: press the unlocking button (1).
- **automatic unlocking**: the fusible link melts when the temperature reaches 72°C in the duct.
- remote unlocking: option: by sending an electrical impulse (VD) or by interrupting the power supply (VM) to the magnet.

Resetting

- **manual resetting**: turn the resetting handle (2) 90° clockwise (or use a 10 mm hex key).
- motorised resetting: (option ME MMAG) switch off the power supply for at least 10 sec. Supply the actuator for at least 30 sec. (respect the prescribed voltage and polarity). The resetting stops automatically if a torque >15 Nm is detected.

Caution:

- ▲ Switch off the power supply after resetting.
- ▲ Switch off the power supply for at least 15 sec. in between each resetting cycle.

Caution:

▲ The mechanism may never be tested on its own, without being attached to the damper. Such a test might damage the mechanism or the operator might be injured.



BFL(T) Remotely controlled spring return actuator

The spring return actuator BFL(T) is specially designed to remotely control fire dampers. The BFL(T) model is intended for fire dampers with smaller dimensions ($\emptyset \le 400 \text{ mm}$ or W+H $\le 1200 \text{ mm}/1400 \text{ mm}$ for CU-LT, CU-LT-1s).

- 1. locking button
- 2. plug (ST)
- 3. access for manual resetting
- 4. thermo-electric tripping device (T)



Options - at the time of order

| SN2 BFL/BFN | Bipolar beginning and end of range switch |
|-------------|---|
| IXI-R1 | Universal field controller (Modbus, BACnet or analog connection), pre-mounted on the damper. |
| IXI-R2 | Universal field controller (Modbus, BACnet), pre-mounted on the damper and with a connection for a second |
| | damper. |

Unlocking

- manual unlocking: place the locking button on "unlock". (In case of BFLT: the damper can alternatively be unlocked by pushing the "test" button on the thermo-electric fuse)
- automatic unlocking: the thermo-electric fuse reacts as soon as the temperature reaches 72°C (type BFLT).
- **remote unlocking**: by interrupting the power supply.

Caution:

▲ The thermo-electric fuse will not move the damper into its safety position (when the temperature reaches 72°C) if the motor is not powered.

Resetting

- manual resetting: turn the enclosed handle anti-clockwise. To block the motor, place the locking button on "lock"
- motorised resetting: switch off the power supply for at least 10 seconds. Supply the actuator (respect the prescribed voltage) for at least 75 seconds. The resetting stops automatically when the end of range is reached (damper open) it takes about 60 seconds to reset the damper or when the power supply is interrupted.

Caution:

- Do not use a drill or screwing machine.
- ▲ Stop as soon as the motor is completely rearmed (end of range).


Caution:

▲ The mechanism may never be tested on its own, without being attached to the damper. Such a test might damage the mechanism or the operator might be injured.

| | | prod. < | 1/7/2015 | | prod. ≥ 1/7/2015 | | | | |
|---------|----------|----------|----------|----------|------------------|----------|----------|----------|--|
| | CR60(1s) | CU-LT | CR2≤400 | CR2>400 | CR60(1s) | CU-LT | CR2≤400 | CR2>400 | |
| | CR120 | CU-LT-1s | CU2≤1200 | CU2>1200 | CR120 | CU-LT-1s | CU2≤1200 | CU2>1200 | |
| Kit BFL | | | | | • | • | • | | |
| Kit BFN | • | • | • | | | | | • | |
| Kit BF | • | | | | | | | | |

Electrical connection

Electrical connection



| MEC | Nominal voltage motor | Nominal voltage magnet | Power consumption (stand-by) | Power consumption (operating) | standard switches | |
|-----------|-----------------------------------|---|------------------------------|---|-----------------------|--|
| MFUS | N/A | N/A | N/A | N/A | 1mA1A, DC 5VAC 48V | |
| MMAG | 24/48 V DC (automatic conversion) | 24/48 V DC (automatic conversion in FDCU printed circuit / entrance capacity: 25 μF) | VM: 1,9W / VD: - / ME: - | VM: - / VD: 3,5W / ME: Pmax 10W (24V)/15W (48V) | 1mA500mA, DC 5VAC 48V | |
| BFL24 | 24 V AC / 24 V DC | N/A | 0,7W | 2,5W | 1mA3A, AC 250V | |
| BFL24-ST | 24 V AC / 24 V DC | N/A | 0,7W | 2,5W | 1mA3A, AC 250V | |
| BFLT24 | 24 V AC / 24 V DC | N/A | 0,8W | 2,5W | 1mA3A, AC 250V | |
| BFLT24-ST | 24 V AC / 24 V DC | N/A | 0,8W | 2,5W | 1mA3A, AC 250V | |
| BFL230 | 230 V AC | N/A | 1,1W | 3,5W | 1mA3A, AC 250V | |
| BFLT230 | 230 V AC | N/A | 1,4W | 4W | 1mA3A, AC 250V | |

| running time motor | running time spring | noise level motor | noise level spring | connection supply / control | Connection auxiliary switch | Protection class |
|-----------------------|------------------------|----------------------|-----------------------|--|--|------------------|
| N/A | 1 s | N/A | N/A | | | IP 42 |
| < 30 s | 1 s | ≤ 66 dB (A) | N/A | | | IP 42 |
| < 60 s | 20 s | ≤ 45 dB (A) | ca. 63 dB (A) | 1 m, 2 x 0.34 mm ² (halogen-free) | 1 m, 6 x 0.75 mm ² (halogen-free) | IP 54 |
| < 60 s | 20 s | ≤ 45 dB (A) | ca. 63 dB (A) | 1 m, 2 x 0.75 mm ² (halogen-free) | 1 m, 6 x 0.75 mm ² (halogen-free) | IP 54 |
| < 60 s | 20 s | ≤ 45 dB (A) | ca. 63 dB (A) | 1 m, 2 x 0.34 mm ² (halogen-free) | 1 m, 6 x 0.75 mm ² (halogen-free) | IP 54 |
| < 60 s | 20 s | ≤ 45 dB (A) | ca. 63 dB (A) | 1 m, 2 x 0.75 mm ² (halogen-free) | 1 m, 6 x 0.75 mm ² (halogen-free) | IP 54 |
| < 60 s | 20 s | ≤ 45 dB (A) | ca. 63 dB (A) | 1 m, 2 x 0.75 mm ² (halogen-free) | 1 m, 6 x 0.75 mm ² (halogen-free) | IP 54 |
| < 60 s | 20 s | ≤ 45 dB (A) | ca. 63 dB (A) | 1 m, 2 x 0.75 mm ² (halogen-free) | 1 m, 6 x 0.75 mm ² (halogen-free) | IP 54 |

Weights

| 388 | 00.1 | 0.00 | |
|------|------|------|----------|
| 1000 | 100 | | |
| | w | 1941 | d, u |

CR120 + MFUS

| ØDn [mm] | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 1,6 | 1,8 | 2,0 | 2,1 | 2,5 | 2,6 | 3,3 | 4,1 | 4,2 | |

CR120 + MMAG

| ØDn [mm] | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,1 | 2,3 | 2,5 | 2,6 | 3,0 | 3,1 | 3,8 | 4,6 | 4,7 | |

CR120 + BFL24

| ØDn [mm] | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,3 | 2,5 | 2,7 | 2,8 | 3,2 | 3,3 | 4,0 | 4,8 | 4,9 | |

CR120 + BFL24-ST

| ØDn (mm) | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,3 | 2,5 | 2,7 | 2,8 | 3,2 | 3,3 | 4,0 | 4,8 | 4,9 | |

CR120 + BFLT24

| ØDn (mm) | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,4 | 2,6 | 2,8 | 2,9 | 3,3 | 3,4 | 4,1 | 4,9 | 5,0 | |

CR120 + BFLT24-ST

| ØDn [mm] | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,4 | 2,6 | 2,8 | 2,9 | 3,3 | 3,4 | 4,1 | 4,9 | 5,0 | |


CR120 + BFL230

| ØDn [mm] | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,3 | 2,5 | 2,7 | 2,8 | 3,2 | 3,3 | 4,0 | 4,8 | 4,9 | |

CR120 + BFLT230

| ØDn (mm) | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|
| kg | 2,4 | 2,6 | 2,8 | 2,9 | 3,3 | 3,4 | 4,1 | 4,9 | 5,0 | |

Selection graphs



$\Delta p [Pa] = \zeta^* v^{2*} 0.6$

| ØDn [mm] | 100 | 125 | 150 | 160 | 180 | 200 | 250 | 300 | 315 | |
|----------|------|------|-----|------|------|------|------|------|------|--|
| ζ [-] | 0,87 | 0,73 | 0,6 | 0,56 | 0,48 | 0,42 | 0,29 | 0,19 | 0,18 | |

Example

Data

Dn= 250mm, v= 5m/s

Requested

Δp= ca. 4.3 Pa (Cfr. selection graph)

LWA= ca. 42 dB(A)

Calculation

 $\Delta p = 0.29 * (5m/s)2 * 0.6 = 4.35Pa$

Selection data

CR120 - A-weighted sound power level in the duct

| | 0.45 | 000 | 050 | 000 | 400 | 400 | 450 | 405 | 400 | 63. 1. 1. |
|-------|----------|----------|----------|--------|--------|--------|--------|--------|--------|-----------------------|
| | 315 | 300 | 250 | 200 | 180 | 160 | 150 | 125 | 100 | ØDn (mm) |
| | 0,0672 | 0,0605 | 0,0407 | 0,0248 | 0,0195 | 0,0149 | 0,0128 | 0,0082 | 0,0047 | Sn [m²] |
| | 86,82 | 86,18 | 83,52 | 79,58 | 77,41 | 74,79 | 71,43 | 68,23 | 61,06 | Sn [%] |
| 45 dB | 1.796,56 | 1.606,00 | 1.043,33 | 615,95 | 482,00 | 362,52 | 312,00 | 200,68 | 116,83 | Q [m³/h] |
| 43 UD | 4,34 | 5,00 | 6,00 | 7,41 | 8,00 | 8,45 | 9,00 | 9,03 | 9,01 | Δp [Pa] |
| 40 dB | 1.247,67 | 1.115,00 | 724,57 | 427,76 | 335,00 | 251,77 | 217,00 | 139,37 | 81,14 | Q [m ³ /h] |
| 40 UD | 2,09 | 2,00 | 2,89 | 3,57 | 4,00 | 4,07 | 4,00 | 4,35 | 4,35 | Δp [Pa] |
| 35 dB | 866,49 | 774,00 | 503,20 | 297,07 | 232,00 | 174,85 | 151,00 | 96,79 | 56,35 | Q [m³/h] |
| og ub | 1,01 | 1,00 | 1,39 | 1,72 | 2,00 | 1,97 | 2,00 | 2,10 | 2,10 | Δp [Pa] |
| 30 dB | 601,76 | 538,00 | 349,46 | 206,31 | 161,00 | 121,43 | 105,00 | 67,22 | 39,13 | Q [m³/h] |
| 30 UD | 0,49 | 1,00 | 0,67 | 0,83 | 1,00 | 0,95 | 1,00 | 1,01 | 1,01 | Δp [Pa] |
| 25 dB | 417,91 | 374,00 | 242,70 | 143,28 | 112,00 | 84,33 | 73,00 | 46,68 | 27,18 | Q [m³/h] |
| 2J UD | 0,23 | 0,00 | 0,32 | 0,40 | 0,00 | 0,46 | 0,00 | 0,49 | 0,49 | Δp [Pa] |


Every air flow lower than the above mentioned maximum value, will meet the listed A-weighted sound power level for the respective dimension.

Correction factor AL

To obtain the sound power level for the octave midband: LW oct = $\Delta L + Lwa$

| [Hz] | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
|-------------|----|-----|-----|-----|------|------|------|------|
| 2 - 4 m/s | 24 | 7 | -6 | -16 | -23 | -26 | -25 | -18 |
| 6 - 8 m/s | 20 | 10 | 0 | -6 | -10 | -14 | -21 | -24 |
| 10 - 12 m/s | 14 | 6 | 0 | -4 | -6 | -9 | -13 | -19 |

Sample order



- 1. product
- 2. diameter
- 3. mechanism type
- option: type magnet and voltage option: resetting motor option: uni/bipolar switches

Approvals and certificates

All our dampers are submitted to a number of tests by official test institutes. Reports of these tests form the basis for the approvals of our dampers.



The NF-label guarantees: conformity with the standard NF S 61-937 Parts 1 and 5: "Systèmes de Sécurité Incendie Dispositifs Actionnés de Sécurité"; conformity with the national decree of March 22, 2004, changed on 14 March 2011 for the classification of fire resistance; the values of the characteristics mentioned in this document. Organisme Certificateur: AFNOR Certification, 11 Rue Francis de Pressensé, F93571 La Plaine Saint-Denis Cedex; Website: http://www.afnor.org http://www.marquage-nf.com; Phone: +33 (0)1.41.62.80.00, Fax: +33 (0)1.49.17.90.00, Email: certification@afnor.org